



Jim Doyle, Governor
Mary P. Burke, Secretary

May 1, 2007

G.A. MURDOCK, INC.
GENE APPELWICK
1200 DIVISION AVE S
PO BOX 465
MADISON SD 57042

Re: Description: FITTINGS, PVC
Manufacturer: G.A. MURDOCK, INC.
Product Name: MUR-LOK R/O PAL
Model Number(s): A-0630405, A-0630415, A-0630425, A-0630605, A-0630615, A-0630625, A-0630825, A-0830405, A-0830415, A-0830425, A-0830605, A-0830615, A-0830625, A-0830825, A-1030405, A-1030415, A-1030425, A-1030605, A-1030615, A-1030625, A-1030825, A-1430405, A-1430415, A-1430425, A-1430605, A-1430615, A-1430625, A-1430825, B-0630425, B-0630625, B-0830425, B-830625, B-1030425, B-1030625, B-1430425, B-1430625, C-0830405, C-0830415, C-0830425, C-0830605, C-0830615, C-0830625, C-0830825, E-0840405, E-0840425, E-0840605, E-0840625, and E-0840825
Product File No: 20070195

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2012.

This approval supersedes the approval issued on July 22, 2002, under product file number 20020272.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020272.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following water use(s):
 - a. Cold water distribution piping Aboveground

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov